

पिंपरी चिंचवड महानगरपालिका

अग्निशमन विभाग

Pimpri Chinchwad Municipal Corporation

Fire Department.



File No:-

185

O.W.No:- Fire/01/5PC/ WS / 185 /2021.

Date:- 09/06/2021

SCHOOL FIRE SAFETY NO OBJECTION CERTIFICATE

Token No:- 103321220001496

Token Dt:- 02/06/2021

M/s. S.B.Patil Public School, S. No. 110, Gat.No.1, Ravet, Pune., had applied for Fire Safety NOC of CBSE Board School.

The fire brigade officer has visited the school inspected fire protection system Installed at site and as per his technical remarks this NOC is being issued for above subject to conditions and compliance of following conditions.

- 1) The entire fire fighting system installation installed at the site should be maintained in excellent working condition for fire emergency.
- 2) The Fire extinguishers handling and operational training to be imparted to the teaching/non-teaching/security staff of the school.
- 3) You will carry out refilling and testing of the fire extinguishers and maintain entire fire fighting system from competent person (Govt. Fire Licensed Agency) and submit the certificate (B-Form) in writing every year along with the renewal application.
- 4) You will keep the static water tanks full for emergency.
- 5) Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6) You will keep all passages and corridors free from any obstructions and combustible material.
- 7) "No Smoking boards" "Emergency EXIT" "Assembly Area" and "Emergency Contact Numbers Boards" of Fire, Ambulance, Police, MSEB, shall be always displayed in school to avoid/minimize fire/ emergency situation/risk.
- 8) This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
- 9) All the rules, regulations and conditions of PCMC, from the time to time, shall be binding on you and any violation of these shall be viewed seriously.
- 10) Necessary 'B Form' from Govt. Approved Fire Licensed Agency towards the maintenance and operational working of the fire fighting system installed in building to be submitted to this fire office as per the Sec.3(3)of the Fire Act.2016,for every six months, in month of January and July. failing of which the NOC to be treated as cancelled.
- 11) This School Operational (Utility) fire NOC to issue with respect to the (Part)Final fire NOC No. Fire/02/5B/WS/108/2017., Dt. 06/12/2017. of Fire dept. PCMC.
- 12) This Fire NOC is Renewal & valid up to dt. 31 March 2022 only.

For S. B. PATIL PUBLIC SCHOOL

B. S. Patil

Principal

S. B. Patil Public School
CBSE Affiliation No. : 1130534
S. No. 110, Gat No. 1,
Ravet, Pune - 412 101

S. B. Patil
Manager

C. J. Patil
CHIEF FIRE OFFICER